



Design Span[®] *hp*

Installation, Flashings and Details Guide

Design Span[®] hp

Installation Guide

- Table of Contents -

<i>Section</i>	<i>Page</i>
<i>General Notes</i>	<i>i</i>
<i>Panel Information</i>	<i>1</i>
<i>Clip Information</i>	<i>2</i>
<i>Eave</i>	<i>3</i>
<i>Eave - with Gutter</i>	<i>4</i>
<i>Eave Hem</i>	<i>5</i>
<i>Eave - Wide Batten</i>	<i>6</i>
<i>Fascia Transition / Wall</i>	<i>7</i>
<i>Fascia Transition (3D)</i>	<i>8</i>
<i>Fascia Transition – Wide Batten</i>	<i>9</i>
<i>Gable</i>	<i>10</i>
<i>Side Wall (Rake Wall)</i>	<i>11</i>
<i>Side Wall (Alt. Details)</i>	<i>12</i>
<i>Ridge / Hip</i>	<i>13</i>
<i>Ridge / Hip (Wide Batten)</i>	<i>14</i>
<i>Ridge - Vented</i>	<i>15</i>
<i>Head Wall</i>	<i>16</i>
<i>Eave - High</i>	<i>17</i>
<i>Slope Transition</i>	<i>18</i>
<i>Valley</i>	<i>19</i>
<i>Roof Penetrations</i>	<i>20</i>
<i>Roof Curb (Side Wall Flashing)</i>	<i>21</i>
<i>Roof Curb (Uphill / Downhill Detail)</i>	<i>22</i>
<i>Snow Drag Loads</i>	<i>Appendix A</i>
<i>Drag Load Resistance</i>	<i>Appendix B</i>

General Notes

The attached installation details are intended to be a design aid and do not depict all situations. Modifications are the responsibility of the designer/user and should take into account climate conditions such as wind and snow, governing code requirements, and the actual usage and maintenance of the structure.

Flashings:

Where possible, flashings should be lapped away from prevailing winds. Certain flashings should be supported if it is likely that equipment (ladder, etc.) will be used against them or if foot traffic is anticipated. Check with AEP Span any time you intend to specify a prefinished flashing in a gauge or finish different than the roof panels. It is good practice to specify that all flashings be of the same material (gauge, color, finish) as the roof panels to ensure long-term durability. Field-painted flashings rarely equal the durability and color fastness of factory baked-on paint systems. The enclosed details have minimized the use of exposed fasteners where possible. The edges of flashings have also been shown hemmed to strengthen and to minimize the exposure of cut edges.

Flashing design and fabrication is generally the responsibility of the contractor. For convenience, we have provided some flashing drawings on our website at <http://www.aepspan.com/roof/prodDetailad08.html?id=35> . Applicable Design Span[®] hp flashing part numbers are referenced within this installation guide.

Substrates:

Design Span[®] hp roofing panels can be used over solid substrates or over spaced supports.

Slope Requirements:

Panels should be used on slopes of 2:12 or greater. Inquire for slopes below 2:12.

Panel Attachment:

Consult the Design Span[®] hp fastener attachment schedule or contact your AEP Span representative for proper clip spacing and fastener size, type, and quantities to meet the project's wind uplift (negative) load requirements. The details in this guide show two fasteners per clip. A minimum of two fasteners is always recommended although three fasteners may be required based on panel load requirements.

Condensation, Insulation, & Ventilation:

It is the designer's responsibility to determine the need and composition of condensation control materials including insulation and vapor retarders, as well as ventilation requirements. Metal roofing is susceptible to condensation and its control should be carefully considered. Applications over rigid insulation may require solid blocking/framing for installation of perimeter flashings and drag load fasteners.

Underlayments:

Prior to installation, an underlayment material may be installed over the roof substrate. The designer should select and specify an appropriate material. The specified material must have a non-abrasive top surface that will not mar, scratch, or abrade the underside of the metal panels and flashings.

"Pinning" Requirements:

The panels must only be "pinned" at one location only to resist the "drag" loads caused by the panel weight, live loads, and snow loads. The intensity of the drag load is a function of the slope, the loads involved, and the length of the panels. Panels must not be pinned at more than one location otherwise damages induced by thermal movement will occur. Appendix 'A' gives the drag loads for various slopes and snow loading conditions, and Appendix 'B' shows the number of fasteners required to resist the drag loads.

Thermal Movement:

Both panels and flashings must allow for thermal movement (expansion and contraction) of the materials, especially where long lengths are used. Appropriate gaps or provisions must be provided to accommodate thermal movement.

Snow Design:

If possible, valleys, gutters, roof elevation changes and penetrations should be minimized or eliminated in snow areas. Roof penetrations should be located as close to the ridge or peak of the roof as possible to minimize accumulations of ice and snow and the effects of thermal movement of the roof panels. Premium membrane underlayments should be used. Valleys in snow areas require special consideration due to the accumulation of snow and ice from tributary roof areas.

Valleys:

Valley dimensions must be the proper width to account for slope, snow, ice, and rain conditions. Valleys should receive a premium underlayment since they are susceptible to water buildup. Valleys must have positive slope for drainage and be kept free of debris so that water does not back up and intrude under the panels.

Oil Canning:

Flat metal surfaces often display waviness commonly referred to as 'oil canning'. This can be caused by variations in raw material, processing variations, product handling, or variations in the substrate and roofing underlayments. Oil canning is a characteristic, not a defect, of panels manufactured from light-gauge metal. Panels are available with striations and are factory "corrective leveled" to minimize oil canning. Oil canning is not a cause for panel rejection. Additional information is available upon request.


References:

The Sheet Metal and Air Conditioning Contractors' National Association Inc. (SMACNA) manual is an excellent reference for sheet metal contractors. It's guidelines for underlayments, gutter and downspout size requirements, and expansion/contraction of metals and flashing joints should be followed.


Technical Assistance:

Contact your AEP Span Sales Representative for additional information.






DESIGN SPAN HP PANEL



INSTALLED VIEW








DESIGN SPAN HP





PANEL INFORMATION

DS-01



CLIP INFORMATION


DS-02




DESIGN SPAN HP

EAVE


DS-03



STEP
1





STEP
2




STEP
3

APPLY 3/8" BEAD OF NON-SKINNING BUTYL SEALANT ON BOTH SIDES AND TOP OF MALE PANEL RIB BEFORE ENGAGING FEMALE RIB OF NEXT PANEL






NOTE:
STANDARD FACTORY NOTCH IS 1-1/8". LONG LENGTH PANEL INSTALLATIONS REQUIRE GREATER FIELD NOTCHING DEPTH.



EAVE HEM

DS-05





APPLY CURING SEALANT
TO BOTH SIDES OF RIB
PRIOR TO INSTALLING RIB COVER

PANEL CLIP

DESIGN SPAN HP PANEL

RIB COVER

DESIGN CAUTION:

ROOF SLOPE TRANSITIONS SUCH
AS FASCIAS MAY ESTABLISH AN
UNWANTED POINT OF PANEL
FIXITY. CONTACT YOUR AEP SPAN
REPRESENTATIVE FOR ASSISTANCE.

1/8" RIVET
BOTH SIDES

FIELD CUT PANEL RIBS
AND BEND OVER EDGE. SEAL
OPEN ENDS OF ROOF PANEL RIBS
WITH CURING SEALANT
BEFORE INSTALLING RIB COVER

DESIGN SPAN HP PANEL

SPECIFIED UNDERLAYMENT
(NOT BY AEP-SPAN)

PANEL CLIP
(CONTACT AEP-SPAN FOR
CLIP LOCATION & SPACING)

SUBSTRATE

PANCAKE HEAD
FASTENERS

1/4" MIN. CLEARANCE
FOR WEEPAGE

FIELD NOTCH
AND HEM 1"
(OPTIONAL FACTORY
PANEL NOTCH)

DRIP FLASHING
(DF009)

SHOULD BE MINIMUM 1/4" GREATER
THAN PANEL RIB HEIGHT.

NOTE:

THE USE OF THIS DETAIL IS NOT
RECOMMENDED IN SNOW CLIMATES.



DESIGN SPAN HP




FASCIA TRANSITION /
WALL

DS-07

DESIGN CAUTION:

ROOF SLOPE TRANSITIONS SUCH AS FASCIAS MAY ESTABLISH AN UNWANTED POINT OF PANEL FIXITY. CONTACT YOUR AEP SPAN REPRESENTATIVE FOR ASSISTANCE.



NOTE:

THE USE OF THIS DETAIL IS NOT RECOMMENDED IN SNOW CLIMATES.





DESIGN SPAN HP



FASCIA TRANSITION

DS-08

FIELD CUT SIDES OF BATTEN CAP. NOTCH BOTTOM LEGS OF UPPER PORTION OF BATTEN CAP AS REQUIRED (VARIES PER ROOF SLOPE). BEND LOWER PORTION OF BATTEN CAP INTO PLACE. FASTEN IN PLACE WITH 1/8" RIVETS, BOTH SIDES.



DESIGN CAUTION:
ROOF SLOPE TRANSITIONS SUCH AS FASCIAS MAY ESTABLISH AN UNWANTED POINT OF PANEL FIXITY. CONTACT YOUR AEP SPAN REPRESENTATIVE FOR ASSISTANCE.




DESIGN SPAN HP






FASCIA TRANSITION
(WIDE BATTEN)

DS-09



NOTE:
FIELD CUT FIRST AND
LAST PANELS TO
EQUAL WIDTH






DESIGN SPAN HP




**SIDE WALL
(RAKE WALL)**



DS-11



ALTERNATE UPPER DETAIL



ALTERNATE LOWER DETAIL




DESIGN SPAN HP



RIDGE / HIP

DS-13



NOTE:

* ADDITIONAL FASTENERS MAY
BE REQUIRED IN HIGH SNOW
LOAD AREAS. SEE APPENDIX.




DESIGN SPAN HP



**RIDGE / HIP
(WIDE BATTEN)**

DS-14



NOTES:

- ^Δ CUSTOMER MUST PROVIDE VENT AREA REQUIREMENTS
- * ADDITIONAL FASTENERS MAY BE REQUIRED IN HIGH SNOW LOAD AREAS. SEE APPENDIX.







DESIGN SPAN HP



RIDGE - VENTED

DS-15





NOTE:

* ADDITIONAL FASTENERS MAY BE REQUIRED IN HIGH SNOW LOAD AREAS. SEE APPENDIX.




DESIGN SPAN HP



EAVE - HIGH

DS-17



NOTE:
REFER TO EAVE & RIDGE DETAILS FOR FURTHER
INFORMATION ON PROPER PANEL TERMINATIONS.





DESIGN SPAN HP




SLOPE TRANSITION

DS-18




ROOF JACK



ROOF CURB


CONTACT AEP SPAN REPRESENTATIVE IF ADDITIONAL ROOF PENETRATION INFORMATION IS REQUIRED.



DESIGN SPAN HP

ROOF PENETRATIONS

DS-20



FIELD FABRICATE CURB
FLASHINGS FROM FLAT SHEET

CONTACT AEP SPAN REPRESENTATIVE
IF ADDITIONAL ROOF PENETRATION
INFORMATION IS REQUIRED.

SLOPE

STANDARD ZEE
CLOSURE

FIELD FABRICATE CRICKET
FROM FLAT SHEETS

EQUIPMENT TRIM
(NOT BY AEP-SPAN)

CLEARANCE FOR
THERMAL MOVEMENT
PER CALCULATIONS

CRICKET TO BE
FIELD FABRICATED
FROM FLAT STOCK

FASTENER
(NOT BY AEP-SPAN)

FIELD FABRICATED
HEADWALL TRIM

1/8" RIVET
@ 12" O.C.

FASTENER
(NOT BY AEP-SPAN)

8" MIN

6"

12"

JOGGLE CLEAT
(#JC095)

3/16" x 7/8" CONTINUOUS
BUTYL TAPE

FIELD FABRICATED
HALF VALLEY TRIM

SUBSTRATE

ZEE
CLOSURE
(ZC219)

FASTENER

NOTE:
CURBS 24" WIDE OR GREATER REQUIRE USE OF CRICKETS.
CRICKETS OPTIONAL ON NARROWER CURBS.



DESIGN SPAN HP



ROOF CURB (UPHILL /
DOWNHILL DETAIL)

DS-22

Appendix A: Snow Drag Loads (lbs/lft of panel)

12" Design Span hp

Slope	Ground Snow Load, P_g (psf)								
	25	30	35	40	45	50	55	60	65
2:12	5.0	5.9	7.0	8.0	9.0	9.9	10.9	12.0	12.9
3:12	7.4	8.8	10.3	11.7	13.2	14.6	16.1	17.7	19.1
4:12	9.6	11.5	13.4	15.2	17.2	19.1	21.1	23.0	24.9
5:12	11.6	13.9	16.3	18.6	20.9	23.2	25.7	28.0	30.3
6:12	13.6	16.2	19.0	21.7	24.3	27.1	29.8	32.4	35.2
7:12	15.2	18.3	21.3	24.4	27.5	30.5	33.5	36.5	39.7
8:12	16.8	20.1	23.5	26.9	30.3	33.5	36.9	40.3	43.7
9:12	18.2	21.8	25.4	29.0	32.7	36.3	39.9	43.6	47.2
10:12	19.4	23.2	27.1	31.0	34.8	38.7	42.6	46.5	50.3
11:12	20.4	24.6	28.7	32.7	36.8	40.9	45.0	49.0	53.1
12:12	21.4	25.7	29.9	34.2	38.5	42.8	47.1	51.3	55.7

16" Design Span hp

Slope	Ground Snow Load, P_g (psf)								
	25	30	35	40	45	50	55	60	65
2:12	6.7	8.0	9.3	10.6	12.0	13.3	14.6	16.0	17.2
3:12	9.8	11.7	13.7	15.6	17.7	19.6	21.5	23.5	25.4
4:12	12.7	15.2	17.9	20.4	23.0	25.5	28.1	30.6	33.2
5:12	15.5	18.6	21.7	24.8	28.0	31.0	34.1	37.3	40.3
6:12	18.0	21.7	25.3	28.9	32.4	36.1	39.7	43.3	46.9
7:12	20.3	24.4	28.4	32.5	36.5	40.7	44.8	48.8	52.9
8:12	22.4	26.9	31.3	35.8	40.3	44.8	49.2	53.7	58.2
9:12	24.2	29.0	33.9	38.7	43.6	48.4	53.2	58.1	62.9
10:12	25.8	31.0	36.2	41.3	46.5	51.7	56.7	62.0	67.2
11:12	27.2	32.7	38.1	43.6	49.0	54.5	60.0	65.5	70.9
12:12	28.6	34.2	39.9	45.6	51.3	57.0	62.8	68.5	74.2

Notes:

- To determine drag load forces per panel, multiply the tabulated value by the panel length. Then refer to Appendix B for fastener schedule.
- Values assume Ground Snow Load (P_g) is provided. Drag Loads may be reduced if actual Roof Snow Loads (F_s), per ASCE-7, are provided by customer.
- For roof slopes and snow loads greater than listed above, please contact your AEP Span representative.

Appendix A: Snow Drag Loads (lbs/ft of panel)

17" Design Span hp

Slope	Ground Snow Load, P_g (psf)								
	25	30	35	40	45	50	55	60	65
2:12	7.0	8.5	9.9	11.3	12.7	14.0	15.5	16.9	18.3
3:12	10.4	12.5	14.5	16.6	18.8	20.8	22.9	24.9	27.0
4:12	13.6	16.2	19.0	21.7	24.4	27.1	29.8	32.5	35.2
5:12	16.5	19.7	23.1	26.4	29.6	32.9	36.3	39.6	42.8
6:12	19.1	23.0	26.9	30.6	34.5	38.4	42.1	46.0	49.9
7:12	21.5	25.9	30.3	34.6	38.8	43.2	47.6	51.8	56.1
8:12	23.7	28.6	33.3	38.0	42.8	47.6	52.3	57.0	61.8
9:12	25.8	30.9	36.1	41.1	46.3	51.4	56.6	61.7	66.9
10:12	27.5	32.9	38.4	43.9	49.4	54.8	60.4	65.8	71.4
11:12	28.9	34.7	40.5	46.3	52.2	58.0	63.8	69.5	75.3
12:12	30.3	36.4	42.5	48.5	54.6	60.6	66.7	72.7	78.8

18" Design Span hp

Slope	Ground Snow Load, P_g (psf)								
	25	30	35	40	45	50	55	60	65
2:12	7.5	9.0	10.4	12.0	13.4	14.9	16.5	17.9	19.4
3:12	11.0	13.2	15.4	17.7	19.8	22.0	24.2	26.4	28.6
4:12	14.4	17.2	20.1	23.0	25.8	28.7	31.6	34.5	37.3
5:12	17.4	20.9	24.4	28.0	31.5	34.8	38.4	41.9	45.4
6:12	20.3	24.3	28.4	32.4	36.5	40.5	44.6	48.6	52.8
7:12	22.9	27.5	32.1	36.5	41.1	45.7	50.3	54.8	59.4
8:12	25.2	30.3	35.2	40.3	45.3	50.3	55.4	60.4	65.5
9:12	27.2	32.7	38.1	43.6	49.0	54.5	59.9	65.3	70.8
10:12	29.0	34.8	40.7	46.5	52.3	58.1	63.9	69.7	75.5
11:12	30.6	36.8	43.0	49.0	55.2	61.3	67.4	73.6	79.7
12:12	32.1	38.5	44.9	51.3	57.7	64.1	70.5	77.0	83.4

Notes:

- To determine drag load forces per panel, multiply the tabulated value by the panel length. Then refer to Appendix B for fastener schedule.
- Values assume Ground Snow Load (P_g) is provided. Drag Loads may be reduced if actual Roof Snow Loads (E_s), per ASCE-7, are provided by customer.
- For roof slopes and snow loads greater than listed above, please contact your AEP Span representative.

Appendix B:**Drag Load Resistance**

Fastener Type	Substrate	Capacity (lbs)	Number of Fasteners per Panel								
			2	3	4	5	6	7	8	9	10
#12-14 x 1" SD HWH	16ga Steel min.	234	468	702	936	1170	1404	1638	1872	2106	2340
1/4-14 x 7/8" Lap SD HWH	22ga Steel min.	184	368	552	736	920	1104	1288	1472	1656	1840
#14 x 1" Type A Mill. Point HWH	1/2" Plywood min.	128	256	384	512	640	768	896	1024	1152	1280
#14 x 1" Type A Mill. Point HWH	2x Douglas Fir	57	114	171	228	285	342	399	456	513	570
#10-16 x 1" SD Pancake Head	16ga Steel min.	206	412	618	824	1030	1236	1442	1648	1854	2060
#10-16 x 1" SD Pancake Head	22ga Steel min.	154	308	462	616	770	924	1078	1232	1386	1540
#10-12 x 1" Type A Pancake Head	1/2" Plywood min.	108	216	324	432	540	648	756	864	972	1080
#10-12 x 1" Type A Pancake Head	2x Douglas Fir	54	108	162	216	270	324	378	432	486	540

Example:

16" Design Span hp attached to 1/2" plywood.

4:12 slope

30psf snow load

40ft maximum panel length

#10-12 pancake head fasteners used

a) From Appendix A, find the drag load per linear foot of panels: 4:12 & 30psf snow load = 15.2 lbs/ft

b) Multiply the load by the panel length = 15.2lbs/ft X 40ft = 608lbs drag load per panel.

c) Find the drag load in Appendix B.

The nearest value is 648 lbs for Qty=6, #10-12 x 1" type A pancake head fasteners.

Notes:

- Contact your AEP Span representative if there are any questions regarding the use of these appendices.
- Fasteners must be located a minimum of 1" from each other and from the end of the panel.